

AIST.org

June 2023

# Iron & Steel Technology<sup>®</sup>



**2023 AIST President  
Barry T. Schneider**

A Publication of the Association for Iron & Steel Technology



## Safer, More Efficient Water-Cooled Power Cable Changeout

Hazards are ever-present in the steel plant environment, and a heightened awareness and emphasis on safety is a necessary priority for our industry. This monthly column, coordinated by members of the AIST Safety & Health Technology Committee, focuses on procedures and practices to promote a safe working environment for everyone.

### Author

**Karl Schwenk**  
Partner and Director, I<sup>2</sup>r POWER, Canton, Ohio, USA  
karl.schwenk@i2rpower.com

Within the United States-Mexico-Canada (USMCA) steelmaking industry, an estimated 170 electric arc furnaces (EAF) and ladle metallurgical furnaces (LMF) utilizing more than 20 MVA are operating daily — actively using an estimated 1,500 power cables. Approximately 500 EAF and LMF power cables are replaced annually.

The power cable installation and removal procedure is customarily performed in less-than-optimal circumstances. Cable changeouts are conducted in awkward, elevated production environments and depend on the skills of the person performing the task. Safety managers, plant engineers, operations, and maintenance personnel must explore options to increase personnel and equipment safety and reduce downtime.

### Discussion

EAF and LMF power cable changeout requires that maintenance personnel wrestle with the weight of the cable against the effects of gravity while in a lift 30–40 feet off the meltshop floor. The cable is inherently not rigid, and its flexibility contributes to potentially unpredictable movement. Additionally, cable connection points can be difficult to access, further complicating the removal and installation. Experienced, skilled personnel are required for a successful power cable changeout.

Additional considerations are whether the removal and installation are occurring during a planned outage or shutdown, or if the power cable changeout is an emergency procedure. If the latter, the safety of the changeout and the quality of the installation may be compromised

if the threat of reduced production is overshadowing the procedure. Under all conditions, safety protocol and advance preparation for power cable changeout is paramount.

Physical risks to personnel and operating equipment are abundant during EAF power cable changeout. Safety planning and careful selection of operating parts are essential.

Innovative and practical terminal designs, proper storage and lifting options exist to improve safety, ease of installation, and to reduce downtime.

### Innovative, Practical Terminal Designs for Safer Installation Procedure —

Traditionally, EAF and LMF power cables have blade terminals that can be 10–12 inches in length, with eight through-holes. Precise alignment of all eight bolt holes on each end is required. Most traditional installations begin with one terminal end at a time. The second terminal connection is typically more difficult. In many instances, the terminal is manually forced into bolt-hole alignment.

Cylindrical terminals eliminate the time-consuming bolt-hole alignment effort. To accept the cylindrical terminals, the load-end and furnace-end connection points are retrofitted with adapter plates that provide a hinged closure, clamping the cylindrical terminal into position. The hinged closure can be a single- or double-hinged design and can be made of copper or brass. Captive hardware reduces the risk of losing nuts, bolts and disc spring washers.


Implementation of the cylindrical terminal design can be accomplished in two methods. Steelmakers can employ the cylindrical terminal on both cable ends, providing the most safety and time-saving

Comments are welcome.

If you have questions about this topic or other safety issues, please contact [safetyfirst@aist.org](mailto:safetyfirst@aist.org).

Please include your full name, company name, mailing address and email in all correspondence.

Figure 1




*An electric arc furnace (EAF)/ladle metallurgical furnaces (LMF) cylindrical terminal design.*

benefits. Retrofitting both cable terminals, as well as the required adapter connection plates, is a greater investment. Alternatively, retrofitting only one cable terminal is a more cost-effective approach and allows steelmakers to test the cylindrical terminal design. In this latter scenario, the 8-hole traditional blade terminal would be connected first and the cylindrical terminal would be installed next.

In certain instances, converting to a cylindrical terminal may not be possible. When overhead furnace and structural facility components make access to connection points limited, a rotating terminal design can offer benefits beyond a traditional stationary terminal. A rotating terminal can facilitate bolt-hole alignment during changeout. Rotating terminals also mitigate stress on the cover hose, and strain on the internal conductor package, when the furnace lid opens and closes. Installation time, and the time

Figure 2



*An EAF/LMF rotating terminal design with lifting device.*

personnel spend elevated in a man-lift, can be reduced by using a rotating terminal design.

Innovative, practical terminal designs exist to help solve safety and downtime challenges for steelmakers. Newer terminal designs can streamline the cable changeout process. When utilizing state-of-the-art designs, terminal orientation becomes simplified, personnel spend less time in bucket or man-lift equipment, and more time is spent on safer ground.

**Importance of Proper Cable Storage and Lifting Options for Easier Alignment** – Proper cable storage and use of equipment and fixtures engineered specifically for water-cooled EAF and LMF cable handling will enhance the safety of the changeout process. Alignment and orientation challenges in a traditional changeout can be mitigated with proper storage and handling. Storage and lifting options exist to improve safety and reduce downtime.

The environment in which power cables are stored impacts their condition. EAF and LMF power cables should be stored indoors, out of the elements, and at a reasonable ambient temperature. Power cables should not be stored in a coiled state for a prolonged period because this promotes the outer hose covering and the inner core hose to become brittle. Additionally, it is not the ideal state for the internal conductor package. Cables left coiled may retain this spiral shape and hinder the installation process, making it difficult to align the bolt-hole pattern. EAF and LMF cable spares should be stored in a flat state — either hanging vertically or in stackable storage trays. Proper cable storage will safeguard spares and ensure they operate correctly when needed most.

Safe handling of EAF and LMF cables can be improved with proper lifting fixtures. Often there are furnace and facility components directly overhead of terminal connection points — in close proximity to one another — forcing maintenance personnel to work around less-than-optimal conditions when handling cables using an overhead crane.

Figure 3



*Newly manufactured spare cables stacked in trays for safe, portable and flat storage.*

Figure 4



*Newly manufactured spare EAF cables stacked in trays and fitted with custom handles for lifting and/or hanging.*

Proper care of the replacement cable is critical for safer, easier installation. Store EAF or LMF cables — either lying flat or hung vertically — to maintain integrity of the outer hose and internal conductor package. Keep spares dry and at a moderate temperature to ensure they work properly at the time they are critically needed. Review procedures and assess equipment and lifting fixtures to ensure safe

control and alignment, and to reduce duration of risky elevated changeouts.

### Conclusion

Approximately 500 EAF power cables are replaced within the North American steelmaking industry annually. Advance safety planning, preparation and careful selection of operating parts are essential for these changeouts. Equipping power cables with innovative terminal designs and custom lifting fixtures will facilitate handling — improving safety and reducing downtime. Proper flat storage of power cables is essential to prolonging the life of the cable and easing alignment challenges. It is imperative safety managers, plant engineers, operations and maintenance personnel research cable changeout procedures to reduce personnel and operating equipment risk and minimize lost production time. ♦



This paper was presented at AISTech 2022 – The Iron & Steel Technology Conference and Exposition, Pittsburgh, Pa., USA, and published in the AISTech 2022 Conference Proceedings.